



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Ottawa County
Green Valley MHP
Community Water System
PWS ID. #: 6201212

February 22, 2007

OH6201212

GREEN VALLEY MOBILE HOME PARK

2/22/2007

Mr. Joseph Street
Green Valley MHP
1795 Elliston - Trowbridge Rd.
Elmore, Ohio 43416



Dear Mr. Street:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of January 2007 on February 5, 2007.

However, OAC Rule 3745-83-01 requires that in addition to operational tests already completed by Green Valley MHP, plant production or gallons per day produced by the water treatment plant be recorded daily and reported on EPA5002. If your plant does not have a water meter, a water meter shall be installed in consultation with Debbie Ko, District Engineer (419-373-3106).

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Ottawa County Health Department
<DDAGW, NWDO File>

ec: Debbie Ko, DDAGW, NWDO