



State of Ohio Environmental Protection Agency

OH6201312

GREENWOOD MOBILE HOME PK

1/30/2009

Northwest

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-
www



Re: Ottawa County
Greenwood MHP
Community Water System
PWS ID# 6201312

January 30, 2009

Ms. Dawn Angel
2186 West Lakeshore Drive
Port Clinton, Ohio 43452

Dear Ms. Angel:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of December 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) in accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(G). OAC Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The January monthly operational report should be submitted to the district office no later than February 10th].

The owner / operator of Greenwood MHP is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I) for not completing the above requirements.

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of October to December 2008.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [e.g., The first calendar quarter (January - March) should be submitted to the district office no later than April 10th.]

The owner / operator of Greenwood MHP is in violation of OAC Rule 3745-81-70(E) for not meeting the aforementioned requirement.

In addition, Greenwood MHP is classified as a Class A public water system in accordance with OAC Rule 3745-7-03(B)(3). OAC Rule 3745-7-02(A)(1) states that, "Each person owning or operating a public water system, except as provided for in paragraph (B) or (E) of this rule, shall designate one or more operator of record to oversee the technical operation of the public water system... Each operator of record shall have a valid certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant."

Ms. Dawn Angel
January 30, 2009
Page Two

A certified Class A operator must be placed in responsible charge of your water system as the operator of record and an operator notification form must be completed and submitted to Ohio EPA. The operator notification form is attached to this correspondence.

The owner/operator of Greenwood MHP is in violation of OAC Rule 3745-7-02(A)(1) for not employing a certified operator to operate and maintain the system.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

with attachment

/lb

pc: Ottawa County Health Department
Toni Buchanan, IMS, DDAGW, CO
~~DDAGW; NWDO File~~