



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ottawa County
Greenwood MHP
Community Water System
PWS ID# 6201312

October 1, 2008

OH6201312

GREENWOOD MOBILE HOME PK

10/1/2008

Ms. Dawn Angel, Vice President
2186 West Lakeshore Drive
Port Clinton, Ohio 43452



Dear Ms. Angel:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of August 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) in accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(G). OAC Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The September monthly operational report should be submitted to the district office no later than October 10th].

The owner / operator of Greenwood MHP is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I) for not completing the above requirements.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Ottawa County Health Department
Toni Buchanan, IMS, DDAGW, CO
DDAGW, NWDO File