



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor.  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
Greenwood MHP  
Community Water System  
PWS ID# 6201312

May 23, 2008

OH6201312

GREENWOOD MOBILE HOME PK

5/23/2008

Ms. Dawn Angel, Vice President  
2186 West Lakeshore Drive  
Port Clinton, Ohio 43452



Dear Ms. Angel:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Reports (EPA 5002) (MOR) were not received for the public water system for the month of April 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) in accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(G). OAC Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The April monthly operational report should be submitted to the district office no later than May 10<sup>th</sup>].

**The owner / operator of Greenwood MHP is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I) for not completing the above requirements.**

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Ottawa County Health Department  
Toni Buchanan, IMS, DDAGW, CO

DDAGW, NWDO File