



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ottawa County
Greenwood MHP
Community Water System
PWS ID# 6201312

August 31, 2007

OH6201312

GREENWOOD MOBILE HOME PK

8/31/2007

Ms. Dawn Angel, Vice President
2186 West Lakeshore Drive
Port Clinton, Ohio 43452



Dear Ms. Angel:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of July 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The July monthly operational report must be submitted to the district office no later than August 10th].

The owner / operator of Greenwood Mobile Home Park is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I).

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Ottawa County Health Department
Toni Buchanan, IMS, DDAGW, CO
~~DDAGW, NWDO, File, Greenwood, MHP~~