



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
Greenwood MHP  
Community Water System  
PWS ID# 6201312

July 25, 2007

OH6201312

GREENWOOD MOBILE HOME PK

7/25/2007

Ms. Dawn Angel, Vice President  
2186 West Lakeshore Drive  
Port Clinton, Ohio 43452



Dear Ms. Angel:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of June 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The July monthly operational report should be submitted to the district office no later than August 10<sup>th</sup>].

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of April to June 2007.

Disinfection residual measurements are required to be taken for total chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10<sup>th</sup> of the month following the end of the calendar quarter being reported. [e.g., The third calendar quarter (July - September) should be submitted to the district office no later than October 10<sup>th</sup>.]

The owner / operator of Greenwood Mobile Home Park is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I), and OAC Rule 3745-81-70(E).

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Ottawa County Health Department  
Toni Buchanan, IMS, DDAGW, CO  
~~DDAGW, NWDO-File~~