



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ottawa County
Village of Oak Harbor
Community Water System
PWS ID. NO: 6202603

September 24, 2008 ^{BR}_{XB}

Mr. Jerry Neff, Superintendent
Village of Oak Harbor
355 E. Water Street
Oak Harbor, Ohio 43449-1456

OH6202603

OAK HARBOR VILLAGE PWS

9/24/2008



Re: 2007 Consumer Confidence Report

Dear Mr. Neff:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for the Village of Oak Harbor on June 9, 2008. The CCR was reviewed for the required content. Based on our review, the Village of Oak Harbor water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants contained inaccurate information. The reported quarterly running annual average level and the range of detection reported for Total Trihalomethanes (TTHM) is incorrect. The running annual average level and range of detection for Haloacetic Acids Five (HAA5) is incorrect. (TTHM: level found = 53.2, range = 28.4 to 82.3, HAA5: level found = 21.6, range = 7.8 to 39.5).

Lead and total coliform were non-detect and should not be included in the table. Copper must have a statement that 0 of 10 samples exceeded the action level for copper of 1300 ug/L.

2. The Total Chlorine residual levels must be reported in the table. (These levels can be found on the Total Chlorine Residual Quarterly Operating Reports, form 5114.)

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website: www.epa.state.oh.us/ddagw.

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Ottawa County Health Department
DBAGW-NWDO-File