



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ottawa County
Ottawa County Regional Water
Community Water System
PWS ID# 6205011


OH6205011

OTTAWA COUNTY REGIONAL

1/15/2008

January 15, 2008

Mr. James K. Frey, Sanitary Engineer
Ottawa County Sanitary Engineering Dept.
315 Madison St. Room 105
Port Clinton, Ohio 43452



Dear Mr. Frey:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Review of your December 2007 operational report indicates that free/combined chlorine residuals were not taken on two days during the month.

Free and combined chlorine residuals are to be conducted at the plant tap and in the distribution system daily (7 days per week).

Yours truly,

Debbie Ko
Division of Drinking and Ground Waters

/csl

Enclosure

pc: Ronald Wetzel, Superintendent
Ottawa County Health Department
DDAGW, NWDO