



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
Village of Put-in-Bay  
Community Water System  
PWS ID# 6203311

May 4, 2010

OH6203311

PUT-IN-BAY VILLAGE PWS

5/4/2010

Mr. David DeZeeuw  
Village of Put-in-Bay  
PO Box 481  
Put-in-Bay, OH 43456



**Subject: Incomplete Monitoring Reports**

Dear Mr. DeZeeuw:

We have received the Drinking Water Contaminant/Operation Report (EPA 5109) for February and March 2010. Ohio Administrative Code (OAC) Rule 3745-83-01(I) requires monitoring and reporting, including analysis of general parameters relating to the quality of treated drinking water. Some items were missing in the reports.

Specifically, the following items were missing:

- The Percent within Standard for the turbidity readings was not reported either month.
- On the March 2010 report the Turbidity Location was also not reported.
- The turbidity for March 14, 2010 was not reported.

If the turbidity monitoring location is the clearwell, the turbidity should be reported even though the Multi-Tech systems did not operate that day.

If you have any questions, please contact me at (419)373-3106.

Yours truly,

Debbie Ko  
Division of Drinking and Ground Waters

/lb

Enclosure

PC: Andrew Barienbrock, DDAGW, CO  
Mr. Doug Knauer, Village Administrator  
Ottawa County Health Department

~~BBAGW, NWDO File~~

