



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Paulding County  
Community PWS  
Village of Antwerp  
PWS ID# OH 6300012  
STU ID# 6357096


July 26, 2011

OH6300012

ANTWERP VILLAGE WATER

7/26/2011

Ms. Sara Keeran, Administrator  
Village of Antwerp  
P. O. Box 1046  
Antwerp, Ohio 45813



Dear Ms. Keeran:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Village of Antwerp has not complied with requirements issued during this Agency's last survey performed on May 25, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. **The PWS was notified in correspondence dated June 20, 2011, to respond in writing no later than 30 days, with time frames for:**

- 1.) OAC Rule 3745-7-09 (A) specifies "The owner and operator of record of a public water system, treatment works or sewerage system shall maintain or cause to be maintained operation and maintenance records for each public water system, water treatment plant within a public water system, treatment works, or wastewater treatment facility within a treatment works." Specifically, the log currently maintained fails to address the following items:
  - a. 3(a) Identification of the public water system;
  - b. 3(b) Date and times of arrival and departure for the operator of record and any other operator required by this chapter; and
  - c. 3(f) Identification of the persons making entries.

Log entries shall be expanded to include the above information.


Ms. Sara Keeran, Administrator  
July 26, 2011  
Page 2

- 2.) The broken access cover on the reaction tank that has been temporarily covered with a metal plate must be replaced with a watertight lid in accordance with the Recommended Standards for Water Works (RSWW) 7.0.3 to avoid potential contamination and to eliminate a sanitary risk.

**The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.**

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3101.

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Paulding County Health Department  
OEPA Central Office, DDAGW  
~~DDAGW, NWDO, File~~