



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH6300012

ANTWERP VILLAGE WATER

7/15/2011



Re: Paulding County  
Community PWS  
Village of Antwerp  
PWS ID# OH6300012  
STU ID# 6357096

July 15, 2011

Ms. Sara Keeran, Administrator  
Village of Antwerp  
P. O. Box 1046  
Antwerp, Ohio 45813

**Violation of the secondary standard for iron - NOV OAC 3745-82-02**

Dear Ms. Keeran:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported Iron greater than three-tenths milligrams per liter (mg/l ) on June 2, 2011.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There was one (1) week during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:


- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Ms. Sara Keeran, Administrator  
July 15, 2011  
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

//lr

pc: Paulding County Health Department  
DDAGW-NWDO.File