



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH6300212

BRENTWOOD COMMUNITY MHP LLC

9/30/2011



Re: Paulding County
Brentwood Community MHP LLC
Community Public Water System
PWS ID# 6300212
STU ID# 6357097

September 30, 2011

Mr. Tim Smith
Midwest Property Management
103 A Degroff Avenue
P. O. Box 218
Archbold, Ohio 43502

Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap

Dear Mr. Smith:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system August 5, 15, 16, 17, 18, 19, 22, 23, 24, 25, 26, 27, and 28.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on August 19, 23, 24, and 25.

Failure to take action to address this violation may result in enforcement action being taken.

Mr. Tim Smith
September 30, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Thomas Roth, Operator
Paulding County Health Department
DDAGW-NWDO File 3