



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Paulding County
Brentwood Community MHP LLC
Community Public Water System
PWS ID# OH6300212

OH6300212

BRENTWOOD COMMUNITY MHP LLC

11/5/2010

November 5, 2010

Mr. Tim Smith, Administrative Contact
103 A Degroff Ave
PO Box 218
Archbold, OH 43502



Notice of Violation – Monthly Report

Dear Mr. Smith:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) for the September 2010 Reporting Period reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on September 15, 16, 19, 20, 21 and 22, 2010.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

In addition, an investigation should be conducted to determine the reason for the plant tap chlorine residuals to be significantly lower than residuals reported in the distribution system on many days. The results of the investigation should be submitted in writing to my attention.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us

Sincerely,

Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

cc: Thomas Roth, Operator of Record
Paulding County Health Department

~~NWDO-DDAGW~~

