



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Karleski, Director

Re: Paulding County
Brentwood Community MHP LLC
Community Public Water System
PWS ID# OH6300212

September 20, 2010

OH6300212

BRENTWOOD COMMUNITY MHP LLC

9/20/2010

Mr. Tim Smith, Administrative Contact
103 A Degroff Avenue
P. O. Box 218
Archbold, Ohio 43502



Notice of Violation – Monthly Report

Dear Mr. Smith:

The Plant-Distribution Monthly Operation Report (EPA Form 5002) for the August 2010, Reporting Period reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on August 14, 23, 25, 26, 27, 28, and 29, 2010.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

/llr

pc: Thomas Roth, Operator of Record
Paulding County Health Department
◀DDAGW-NWDO File - - - - -▶