



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Paulding County
Brentwood Community MHP LLC
Community Public Water System
PWS ID# OH6300212


OH6300212

BRENTWOOD COMMUNITY MHP LLC

6/9/2010

June 9, 2010

Mr. Tim Smith, Administrative Contact
103 A Degroff Avenue
PO Box 218
Archbold, OH 43502



Notice of Violation – Monthly Report

Dear Mr. Smith:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on May 1, 6, 7, 8, 17, 21, 22, 23, 24, 25, 2010.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us

Sincerely,

Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

cc: Ann Scott, Operator of Record
Paulding County Health Department

NWDO - DBAGW

