



State of Ohio Environment

OH6300212


BRENTWOOD COMMUNITY MHP LLC

5/6/2010

Northwest District

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461
www.epa.oh



Re: Paulding County
Brentwood Community MHP LLC PWS
PWS ID#OH6300212

May 6, 2010

Ms. Ann Scott
333 Benton Road
Sycamore, Ohio 44882-9641

Dear Ms. Scott:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by Ohio EPA on April 12, 2010; not signed by the designated operator of record; and reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on March 27 & 28, 2010.

Ohio Administrative Code (OAC) Rule 3745-83-01(l)(2) requires the operation report to be submitted to the district office no later than the tenth of the month following the month for which the report was prepared and also requires the report to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

More than one operator of record may be designated to oversee the technical operation of the public water system by completion and return of the enclosed Operator of Record Notification Form to the Operator Certification Unit.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take actions to address these violations may result in enforcement action being taken.

Questions may be directed to my attention by contacting me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us.

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

/llr

pc: Tim Smith, Administrative Contact
Paulding County Health Department
DDAGW-NWDO File: [unclear]

