



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Paulding County
Brentwood MHP
Community Water System
PWS ID # 6300212


March 17, 2009

OH6300212

BRENTWOOD COMMUNITY MHP LLC

3/17/2009

Mr. Tim Smith, Manager
Brentwood Community, LLC
103 A. DeGross Avenue
P.O. Box 218
Archbold, Ohio 43502



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant-Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for February 2009.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01 (C) (1). There were 13 days during the month of February that the minimum chlorine residual was not maintained throughout the distribution system.

Brentwood Community MHP is in violation of OAC Rule 3745-83-01 (C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the month of February 2009.

Within 15 days, submit a written Action Plan outlining steps you intend or have taken to address this violation.

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

/llr

pc: Thomas Roth, IFM Operator
Toni Buchanan, IMS, DDAGW-CO
Paulding County Health Department
DDAGW, NWDO File