



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Paulding County
Brentwood MHP
Community Water System
PWS ID# 6300212


OH6300212

BRENTWOOD COMMUNITY MHP LLC

2/18/2009

February 18, 2009

Mr. Tim Smith, Manager
Brentwood Community, LLC
103 A DeGross Ave.
PO Box 218
Archbold, Ohio 43502



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for January 2009.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1). There were 15 days during the month of January 2009 that the minimum chlorine residual was not maintained throughout the distribution system.

Brentwood Community MHP is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the month of January 2009.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters
/lb

pc: Thomas Roth, IFM, Operator
Toni Buchanan, IMS, DDAGW, CO
Paulding County Health Department
~~DDAGW, NWDO File~~