



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Paulding County
Brentwood MHP
Community Water System
PWS ID# 6300212

November 26, 2008

OH6300212

BRENTWOOD COMMUNITY MHP LLC

11/26/2008

Mr. Tim Smith, Manager
Brentwood Community, LLC
103 A DeGroff Ave.
PO Box 218
Archbold, Ohio 43502



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for October 2008.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1). *There were 10 days during the month of October that the minimum chlorine residual was not maintained throughout the distribution system.*

Brentwood Community MHP is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the month of October 2008.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Thomas Roth, IFM, Operator (2926 U.S. Highway 6, McClure, Ohio 43534)
Toni Buchanan, IMS, DDAGW, CO
Paulding County Health Department

~~DDAGW-NWDO File~~