



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Paulding County
Brentwood MHP
Community Water System
PWS ID# 6300212


July 30, 2008

OH6300212

BRENTWOOD COMMUNITY MHP LLC

7/30/2008

Mr. Tim Smith, Manager
Brentwood Community, LLC
103 A DeGroff Ave.
PO Box 218
Archbold, Ohio 43502



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Division Distribution Monthly Operation Reports (EPA 5002) (MOR) were received for your public water system for May and June 2008.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1). The maximum residual disinfectant level for total chlorine is 4.0 mg/L in accordance with OAC Rule 3745-81-10(C). The minimum chlorine residual in the distribution system was not maintained multiple days in May and June 2008.

Brentwood MHP is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system.

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of April to June 2008.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [e.g., The third calendar quarter (July - September) should be submitted to the district office no later than October 10th.]

Brentwood MHP is in violation of OAC Rule 3745-81-70(E) for not submitting the required quarterly operating report for the April to June 2008 quarter.

Mr. Tim Smith
July 30, 2008
Page Two

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Toni Buchanan, IMS, DDAGW, CO
Paulding County Health Department
~~DDAGW, NWDO, File~~