



State of Ohio Enviro

OH6300212

BRENTWOOD COMMUNITY MHP LLC

4/30/2008

**Northwest**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-  
www.e



Chris Korleski, Director

Re: Paulding County  
Brentwood MHP  
Community Water System  
PWS ID# 6300212

April 30, 2008

Mr. Tim Smith, Manager  
Brentwood Community, LLC  
103 A DeGroff Avenue  
P.O. Box 218  
Archbold, Ohio 43502

Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Reports (EPA 5002) (MOR) were received for your public water system for February and March 2008.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1).

**Brentwood MHP is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the months of February and March 2008.**

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of January to March 2008.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10<sup>th</sup> of the month following the end of the calendar quarter being reported. [e.g., The first calendar quarter (January - March) should be submitted to the district office no later than April 10<sup>th</sup>.]

**Brentwood MHP is in violation of OAC Rule 3745-81-70(E) for not submitting the required quarterly operating report for the January to March 2008 quarter.**


Mr. Tim Smith, Manager

April 30, 2008

Page 2

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith

Environmental Specialist 2

Division of Drinking and Ground Waters

/llr

pc: Toni Buchanan, IMS, DDAGW, CO  
Paulding County Health Department  
~~DDAGW: NWDO: File~~