



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Paulding County  
Brentwood MHP  
Community Water System  
PWS ID# 6300212


January 22, 2008

OH6300212

BRENTWOOD COMMUNITY MHP LLC

1/22/2008

Mr. Tim Smith, Manager  
Midwest Property Management  
8959 Airport Highway  
Holland, Ohio 43528



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for December 2007.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1).

**The Brentwood MHP is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the month of December 2007.**

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/csf

pc: Toni Buchanan, IMS, DDAGW, CO  
Paulding County Health Department  
C:\DDAGW\NWDO File \