



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH6300312

OAKWOOD VILLAGE WATER

9/30/2011



Re: Paulding County
Community PWS
Village of Oakwood
PWS ID# OH6300312
STU ID# 6357098

September 30, 2011

Mr. John Keyes
Village of Oakwood
228 North First Street
Oakwood, Ohio 45873

Violation of the secondary standard for manganese - NOV OAC 3745-82-02

Dear Mr. Keyes:

Notice of Violation

In violation of Ohio Administrative Code (OAC) 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were 4 weeks during the month of August 2011 in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to chris.riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Paulding County Health Department
NWDO - DDAGW File