



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH6900212

CONTINENTAL VILLAGE WATER

8/22/2011



Re: Putnam County
Village of Continental PWS
Community Public Water System
PWS ID# OH6900212
TU ID# 6957579

August 22, 2011

Mr. Don Wagner, President
Board of Public Affairs
Village of Continental
100 North Main Street
P. O. Box 447
Continental, Ohio 45831

**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Wagner:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system July 15, 16, 18, 19, 20, 24, and 25.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on July 15, 17, and 18 at the plant tap. Investigate the cause of this deficiency and take measures to correct it.

Failure to take action to address this violation may result in enforcement action being taken.

Mr. Don Wagner, President
August 22, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Chris Riddle". The signature is fluid and cursive, with the first name "Chris" written in a smaller, more compact script than the last name "Riddle", which features a large, sweeping "R".

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Putnam County Health Department
Nelson Bear, Operator
~~DDAGW-NWDO:File~~ 