




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH6901412

COUNTRY ACRES GOLF CLUB

9/21/2011



Re: Putnam County  
Country Acres Golf Club PWS  
Community Public Water System  
PWS ID# 6901412

September 21, 2011

Mr. Ron Klausing, President  
Country Acres Golf Club  
17374 State Route 694  
Ottawa, Ohio 45875

**Notice of Violation – Monthly Report – Chlorine Residual Distribution  
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Klausing:

**Notice of Violation**

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l ) and combined chlorine residual of less than one mg/l in the distribution system August 2, 3, 4, 8, 9, 17, 18, 19, 20, 21, 22, 23, 25, 26, 2, 28, 29, 30, & 31.

OAC Rule 3745-83-01(C)(1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

**Notice of Deficiency**

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l ) and combined chlorine residual of less than one mg/l on August 20, 21,23, 24, & 25.

Per Ohio EPA's letter dated July 18, 2011, an update on specific actions planned to address this ongoing violation was due to our office before August 19, 2011. This information has not been received at this time. Notice that this update had not been received was also provided on the Notice of Violation for failure to maintain chlorine residuals issued on August 22, 2011.

Mr. Ron Klausing  
September 21, 2011  
Page Two

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [chris.riddle@epa.state.oh.us](mailto:chris.riddle@epa.state.oh.us).

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs

pc: Jim Hemrick  
Putnam County Health Department  
~~NWDG~~ DDAGW File