



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Putnam County
Country Acres Golf Club PWS
Community Public Water System
PWS ID# 6901412

August 22, 2011

OH6901412

COUNTRY ACRES GOLF CLUB

8/22/2011

Mr. Ron Klausing, President
Country Acres Golf Club
17374 State Route 694
Ottawa, Ohio 45875



**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Klausing:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system July 6, 7, 12, 13, 14, 15, 16, 18, 23, 24, 28, 29, 30, and 31.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Per Ohio EPA’s letter dated July 18, 2011, an update on specific actions planned to address this ongoing violation are due to our office before August 19, 2011. Please submit a written update of your specific plans immediately.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Jim Hemrick
Putnam County Health Department
◀DDAGW-NWDO▶