



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Putnam County  
Country Acres Golf Club PWS  
Community Public Water System  
PWS ID# 6901412


April 28, 2011

OH6901412

COUNTRY ACRES GOLF CLUB

4/28/2011

Mr. Ron Klausing, President  
Country Acres Golf Club  
17374 State Route 694  
Ottawa, Ohio 45875



### Notice of Violation – Monthly Report – Chlorine Residual Distribution

Dear Mr. Klausing:

#### Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l ) and combined chlorine residual of less than one mg/l in the distribution system March 1, 2, 3, 4, and 5.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lir

pc: Putnam County Health Department  
DDAGW-NWDO:File

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)