



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH6901412

COUNTRY ACRES GOLF CLUB

9/27/2010



Re: Putnam County
Country Acres Golf Club
Community Water System
PWS ID# OH6901412
STU ID# 6957589

September 27, 2010

Mr. Ronald Klausing, President
Country Acres Golf Club
17374 State Route 694
Ottawa, Ohio 45875

RE: Notice of Violation – Monthly Report

Dear Mr. Klausing:

The August 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on September 1, 2010.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of the August 2010 report shows 19 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Putnam County Health Department
DDAGW;NWDO;File