



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7003612

COUNTRY MEADOW CARE CENTER

10/6/2011



Re: Richland County
Country Meadow Care Center
Community Water System
PWS ID# OH7003612

October 6, 2011

Mr. Phil Critcher
Country Meadow Care Center
800 Concourse Parkway South, Suite 200
Maitland, Florida 32751

Dear Mr. Critcher:

Ohio Administrative Code (OAC) Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system.

Review of your July 2011 operational report indicates that free chlorine residuals were below this level a total of 4 days during the month.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly,

Curtis A. Eldridge
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
DDAGW, NWDO File