




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7000712

COUNTRYSIDE WATER ASSOCIATION

3/1/2011



Re: Richland County
Dayspring Assisted Living and Care
Community Water System
PWS ID# OH7003312

March 1, 2011

Ms. Kathi Haubiel
Dayspring Assisted Living and Care
3220 Olivesburg Road
Mansfield, Ohio 44903

Dear Ms. Haubiel:

Disinfection monitoring for total chlorine is required by Ohio Administrative Code (OAC) Rule 3745-81-70 at the time routine total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10th of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the October – December 2010 calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
DDAGW, NWDG, File