



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

Re: Richland County  
Crestwood Hills C&R Association  
Community Water System  
PWS ID # 7000812  
-REVISED-

OH7000812 CRESTWOOD HILLS C AND R ASSOCIATION 6/18/2010

June 18, 2010

Mr. Dean Blamer  
Crestwood Hills C&R Association  
1984 Hout Road  
Mansfield, Ohio 44905



Dear Mr. Blamer

The March 2010, Drinking Water Operation Report (EPA 5002) received for your public water system does not meet the requirements as set forth in OAC Rule 3745-83-01.

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis Eldridge  
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department  
CDDAGW,;NWDO,File. \_ >

