



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
Crestwood Hills C&R Association
Community Water System
PWS ID# OH7000812

March 5, 2008

OH7000812

CRESTWOOD HILLS C AND R ASSOCIATION

3/5/2008

Mr. Dean Blamer
Crestwood Hills C&R Association
1984 Hout Road
Mansfield, Ohio 44905



Dear Mr. Blamer:

The January 2008 Drinking Water Operation Report (EPA 5002) for your public water system does not meet the requirements as set forth in Ohio Administrative Code (OAC) Rule 3745-83-01.

OAC Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any questions concerning this matter, please contact me at (419)373-3105.

Yours truly,

Curtis A. Eldridge
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
Tony Weirich, McGhee's Technical Services
~~DDAGW, NWDO File~~