



State of Ohio Envir

OH7000812

CRESTWOOD HILLS C AND R ASSOCIATION

6/12/2007

Northwes

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-
www



Re: Richland County
Crestwood Hills C&R Association
Community Water System
PWS ID# 7000812

June 12, 2007

Mr. Tony R. Weirich
Crestwood Hills C&R Association
1984 Hout Road
Mansfield, Ohio 44905

Dear Mr. Weirich:

The April 2007 Drinking Water Operation Report (EPA 5002) received for your public water system does not meet the requirements as set forth in Ohio Administrative Code (OAC) Rule 3745-83-01.

OAC Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any problems understanding this letter and/or OAC Rule 3745-83-01, please contact me at (419)373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
DDAGW, NWDO File