



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7004112

DAYSPRING ASSISTED LIVING AND CARE

8/16/2011



Re: Richland County  
Dayspring Assisted Living & Care Facility  
Community Water System  
PWS ID# OH7004112

August 16, 2011

Mr. Bill Cunning, Executive Director  
Dayspring Assisted Living and Care Facility  
1469 Troy Drive  
Mansfield, Ohio 44905

Dear Mr. Cunning:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your June 2011 operational reports indicates that free chlorine residuals were below this level a total of 12 days in June 2011.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at [curt.eldridge@epa.state.oh.us](mailto:curt.eldridge@epa.state.oh.us).

Yours truly,

Curtis A. Eldridge  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department  
DBAGW/NWDO-File