




**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH7004112

DAYSRING ASSISTED LIVING AND CARE

10/6/2010



Re: Richland County
Dayspring Assisted Living & Care
Community Public Water System
PWS ID# OH7004112

October 6, 2010

Ms. Kathi Haubiel, Assistant Director of Operations
Dayspring Assisted Living and Care
3220 Olivesburg Road
Mansfield, Ohio 44903

Notice of Violation – Quarterly Operating Report

Dear Ms. Haubiel:


The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Total Chlorine Residual Quarterly Operating Report (EPA 5114, revised April 2004) (QOR) for the April to June 2010 Quarter has not been received.

Disinfection residual measurements are required to be taken for **total chlorine** according to Ohio Administrative Code (OAC) Rule 3745-81-70(E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e. The April – June calendar quarter should have been submitted to the district office no later than July 10th.] The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

The Division of Drinking and Ground Waters has started a web-based monthly report reporting site called eDWR. It may be more convenient for you to submit the monthly reports using eDWR. More information regarding this can be obtained at <http://www.epa.ohio.gov/ddagw/reporting.aspx#edwr>.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via e-mail to curt.eldridge@epa.state.oh.us.

Sincerely,


Curt Eldridge
Division of Drinking and Ground Waters

/cs
pc: Richland County Health Department
NWDO-DBAGW-File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov