



State of Ohio Environmental Protection Agency

Northv

OH7004112

DAYSPRING ASSISTED LIVING AND CARE

5/24/2010

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419



10r
10r
10r

Re: Richland County
Dayspring Assisted Living and Care
Community Water System
PWS ID# OH7003312

May 25, 2010

Ms. Kathi Haubiel, *Asst. Director of Operations*
Dayspring Assisted Living and Care
3220 Olivesburg Road
Mansfield, Ohio 44903

Dear Ms. Haubiel:

Disinfection monitoring for total chlorine is required by OAC Rule 3745-81-70 at the time routine total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10th of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the January - March calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
DDAGW;NWDO;File

