



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7003312

MUSKINGUM WATERSHED CONSER DIST

10/6/2011



Re: Richland County
Muskingum Watershed Conservancy District
Community Water System
PWS ID# OH7003312

October 6, 2011

Mr. Glen Brook
Muskingum Watershed Conservancy District
P. O. Box 349
New Philadelphia, Ohio 44663-0349

Dear Mr. Brook:

The July 2011, Drinking Water Operation Report (EPA 5002) received for your public water system does not meet the requirements as set forth in Ohio Administrative Code (OAC) Rule 3745-83-01.

OAC Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
: DDAGW, NWDO File