



State of Ohio Environmental Protection Agency

North

OH7003312

MUSKINGUM WATERSHED CONSER DIST

5/25/2010

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (614) 324-3300



\* 0 H 7 0 0 3 3 1 2 5 2 5 2 0 1 0 N O V \*

error  
error  
ector

Re: Richland County  
Muskingum Watershed Conservancy District –  
Sites Lake  
Community Water System  
PWS ID# OH7003312

May 25, 2010

Mr. Boris E. Slogar  
Muskingum Watershed Conservancy District  
Sites Lake  
3350 Shad Drive  
Mansfield, Ohio 44905

Dear Mr. Slogar:

Disinfection monitoring for total chlorine is required by OAC Rule 3745-81-70 at the time routine total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10<sup>th</sup> of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the January - March calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge  
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department  
DDAGW, NWDO File