



State of Ohio Environmental Protection Agency

Northw


OH7004712

SHILOH VILLAGE OF

2/19/2010

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419)



10r  
10r  
10r

Re: Richland County  
Village of Shiloh  
Community Water System  
PWS ID# OH7004712

February 19, 2010

Mr. Rick Reeder  
Village of Shiloh  
125 Scott Street  
Shiloh, Ohio 44878

Dear Mr. Reeder:

Ohio Administrative Code (OAC), Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your December 2009 operational reports indicate that free chlorine residuals were below this level a total of 7 days.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at [curt.eldridge@epa.state.oh.us](mailto:curt.eldridge@epa.state.oh.us).

Yours truly,

Curtis Eldridge  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department  
~~DDAGW-NWDO File~~