



State of Ohio E

OH7005112

WILLOW PARK WATER ASSOCIATION

10/31/2007

Northv

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (41



10r
10r
10r

Re: Richland County
Willow Park Water Association
Community Water System
PWS ID# 7005112

October 31, 2007


Mr. Mark Yoder
Willow Park Water Association
1451 Resthaven Drive
Mansfield, Ohio 44903

Dear Mr. Yoder:

Disinfection monitoring for total chlorine is required by Ohio Administrative Code (OAC) Rule 3745-81-70 at the time total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10th of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the July - September 2007 calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,


Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Richland County Health Department
CDDAGW;NWDO-File