




State of

OH7200012

APOLLO MOBILE HOME PARK

8/14/2008

N



347 North Dunbridge Road  
Bowling Green, OH 43402-9398

Governor  
Governor  
Chris Korleski, Director

Re: Sandusky County  
Apollo Mobile Home Park  
Community Water System  
PWS ID#OH7200012

August 14, 2008

Mr. Joseph Binder III  
41051/2 West State Route 20  
Gibsonburg, Ohio 43431

**Subject: 2007 CCR**

Dear Mr. Binder:

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the Apollo Mobile Home Park Public Water System on July 1, 2008. The CCR was reviewed for the required content. Based on our review, the Apollo Mobile Home Park Public Water System is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-02 for failure to comply with the CCR requirements. The following deficiencies were noted:


1. The Table of Detected Contaminants:
  - a. failed to include the following detected contaminants: Bromoform 1.2 µg/l (05/14/07), Chlorodibromomethane 1.9 µg/l (05/14/07), Bromodichloromethane 1.2 µg/l (05/14/07), & Total Haloacetic Acids 13.9 µg/l (05/14/07) (See enclosed Chemical SSR Summary).
  - b. Omitted Total Chlorine.
  - c. Included contaminants with a level found of nondetect: Nitrate and Radium-228 (See enclosed Chemical SSR Summary).
2. Omitted the following mandatory verbage: "Contaminants that may be present in source water include:" (See enclosed OAC rule 3745-96-02 (G)(1)(b))

Be sure to correct the violations as appropriate in your next CCR. The next Consumer Confidence Report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Northwest District Office at the above address. The CCR template and template guide are accessible on our website: [www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

Mr. Joseph Binder III  
August 14, 2008  
Page 2

If you have any questions, please contact me at 419-373-3042.

Sincerely,



Larry W. Moritz  
Division of Drinking and Ground Waters

/llr

pc: Joseph Binder, Jr.  
Chris Henthorn, Clean Water Service Inc.  
Sandusky County Health Department  
(DDAGW/NWDO File ...)