



State of Ohio

OH7400212

BLOOMVILLE VILLAGE PWS

4/27/2007

**North**

TELE:



\* O H 7 4 0 0 2 1 2 4 2 7 2 0 0 7 N O V \*

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

Director

Re: Seneca County  
Village of Bloomville  
Community Water System  
PWS ID # 7400212

April 27, 2007

Board of Public Affairs  
Village of Bloomville  
10 Beeghly Avenue  
Bloomville, Ohio 44818

Dear Mr. Brown:

The Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), has received and reviewed the Plant-Distribution Monthly Operating Report (EPA form 5002) for the month of March 2007.

OAC Rule 3745-83-01(G)(4) states that, "A public water system that adds phosphate to the water supply shall monitor for total phosphate at least monthly at each entry point to the distribution system." The village of Bloomville water treatment plant adds phosphate to the water to sequester iron. Due to the addition of the phosphate the monthly sampling required above must be completed and reported on EPA form 5002.

Ensure that future monthly reports include Total Phosphate sampling in accordance with OAC Rule 3745-83-01(G)(4) in addition to the sampling results already reported.

If you have any questions concerning this matter, please feel free to contact me at (419)373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Darin Brown, Superintendent of Water  
Seneca County Health Department

DDAGW: NWDO File