



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Village of Bloomville
Community Water System
PWS ID # 7400212

February 23, 2007

OH7400212

BLOOMVILLE VILLAGE PWS

2/23/2007

Mr. Darin Brown
Village of Bloomville
10 Beeghly Avenue
Bloomville, Ohio 44818



Dear Mr. Brown:

The Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), has received and reviewed the Plant-Distribution Monthly Operating Report (EPA form 5002) for the month of January 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01(G)(9)(b) states that, "A public water system serving two hundred and fifty or more persons that provides treatment to reduce iron shall monitor for iron at least weekly at each entry point into the distribution system using a state certified laboratory. A public water system serving two hundred and fifty or more persons may reduce the frequency of certified laboratory analyses for iron to no less than once each month provided the following conditions are met:

(i) The public water system monitors once every day that water is available to the public for iron using an in-house test kit at each entry point into the distribution system. The test kit shall have a minimum detection level of 0.2 milligrams per liter for iron; **and**

(ii) The public water system has one split sample analyzed monthly by an in-house test kit and by a certified laboratory. The deviation between results shall be no greater than 0.2 milligrams per liter for iron. If the split sample results for iron vary by more than 0.2 milligrams per liter, the public water system shall resume weekly monitoring using a certified laboratory. A public water system may return to a reduced frequency of certified laboratory analyses for iron once the deviation of split sample results is within the accepted limits specified in this paragraph."

Ensure that future monthly reports include iron sampling in accordance with OAC Rule 3745-83-01(G)(9)(b) in addition to the sampling results already reported.

If you have any questions concerning this matter, please feel free to contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lir

pc: Seneca County Health Department

DDAGW, NWDO File