



State of Ohio Environmental Protection Agency

Northwest

OH7401312

BROOK PARK ESTATES MHP PWS

5/25/2010

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-
www



Re: Seneca County
Brook Park Estates MHP
Community Water System
PWS ID# OH7401312

May 25, 2010

Mr. Michael J. Malone
Brook Park Estates MHP
2400 South Township Road 119
Tiffin, Ohio 44883

Dear Mr. Malone:

Disinfection monitoring for total chlorine is required by OAC Rule 3745-81-70 at the time routine total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10th of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the January - March calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Seneca County Health Department
DDAGW\NWDOTFile