



State of Ohio Envir

OH7401312

BROOK PARK ESTATES MHP PWS

9/29/2008

Northwes

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352
www



Re: Seneca County
Brook Park Estates MHP
Community Water System
PWS ID# 7401312

September 29, 2008

Mr. Michael Malone
Brook Park Estates MHP
2400 S. Township Road 119
Tiffin, Ohio 44883

Re: 2007 Consumer Confidence Report

Dear Mr. Malone:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for the Brook Park Estates MHP on July 7, 2008. The CCR was reviewed for the required content. Based on our review, the Brook Park Estates MHP water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants contained inaccurate information.

The table does not contain columns for the level found and Sample year. The level found is not reported for Total Chlorine, only the range is reported.

Total coliform bacteria was not detected during the 2007 reporting year and therefore does not need to be reported in the table.

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website at www.epa.state.oh.us/ddagw.

Mr. Michael Malone
September 29, 2008
Page 2

If you have any questions, please contact me at 419-373-3101.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

//lr

pc: Seneca County Health Department
DDAGW-NWDO-File →