



State of Ohio

OH7401312

BROOK PARK ESTATES MHP PWS

7/3/2008

North



* 0 H 7 4 0 1 3 1 2 7 3 2 0 0 8 N O V *

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE (

rnor
rnor
Chris Korleski, Director

Re: Seneca County
Brook Park Estates MHP
Community Water System
PWS ID# 7401312

July 3, 2008

Mr. Michael Malone
Brook Park Estates MHP
2400 S. Twp. Rd. 119
Tiffin, Ohio 44883

Dear Mr. Malone:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of May 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The May monthly operational report should be submitted to the district office no later than June 10th].

The owner / operator of Brook Park Estates is in violation of OAC Rule 3745-83-01(I) for not completing and submitting a monthly operating report.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Seneca County Health Department

DDAGW;NWDO;File