



State of Ohio E OH7400411


FOSTORIA CITY

5/24/2007

Northw

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419



\* 0 H 7 4 0 0 4 1 1 5 2 4 2 0 0 7 N O V \*

Chris Korleski, Director

Re: Seneca County  
City of Fostoria  
Community Water System  
PWS ID# 7400411

May 24, 2007

Mr. Bill Rains, Safety Service Director  
City of Fostoria  
213 South Main Street  
Fostoria, Ohio 44830-1007

Dear Mr. Rains:

Review of the Fluoride Adjustment Report (EPA 5011) for the City of Fostoria Water Treatment Plant showed that the fluoride level fell below 0.8 mg/L for 6 days during the month of March 2007. The City of Fostoria WTP is required by ORC 6109.20 to maintain a fluoride concentration in the range of 0.8 mg/L to 1.3 mg/L. Take steps to keep the fluoride level between 0.8 mg/L and 1.3 mg/L. Public notification is not required for this violation.

I trust you will take the necessary steps to correct this deficiency.

Yours truly,

Justin W. Bowerman  
Division of Drinking and Ground Waters

/csl

pc: Ron Fauls, Superintendent  
Seneca County Health Department  
David Evans, DDAGW, E&OS, CO  
Toni Buchanan, DDAGW, CO  
DDAGW, NWDO, File