


John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7400712

FOSTORIA MOBILE ESTATES

3/1/2011



Re: Seneca County  
Fostoria Mobile Estates  
Community Water System  
PWS ID# OH7003312

March 1, 2011


Mr. Joe Raineri  
Fostoria Mobile Estates  
P. O. Box 398  
Bath, Ohio 44210-0398

Dear Mr. Raineri:

Disinfection monitoring for total chlorine is required by Ohio Administrative Code (OAC) Rule 3745-81-70 at the time routine total coliform samples are collected. The results of these samples are to be reported on the Total Chlorine Residual Quarterly Operating Report (EPA 5114) by the 10<sup>th</sup> of the month following the end of the calendar quarter being reported. The Total Chlorine Residual Quarterly Operating Report for the October – December 2010 calendar quarter has not been received for your water system.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

  
Curtis A. Eldridge  
Division of Drinking and Ground Waters

/cs

pc: Seneca County Health Department  
~~DDAGW, NWDO~~:File  
Lucas Stahl, Operator  
Tanushree Courlas, CAS, DDAGW, CO  
DDAGW, IMS, CO  
ec: Erica Spitzig, Attorney General's Office  
David Dokko, Attorney General's Office  
Beth Messer, Enforcement, DDAGW, CO  
JoAnn Sabo, DDAGW, NWDO