



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Fostoria Mobile Estates
Community Public Water System
PWS ID# OH7400712


February 2, 2010

Mr. Joe Raineri
Fostoria Mobile Estates, LLC
P. O. Box 398
Bath, Ohio 44210

OH7400712

FOSTORIA MOBILE ESTATES

2/2/2010



Dear Mr. Raineri:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant – Distribution Monthly Operating Report (EPA 5002) (MOR) was not received for Fostoria Mobile Estates water system for the months of March through December 2009 and January 2010.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily according to Ohio Administrative Code (OAC) Rule 3745-83-01(G). OAC Rule 3745-83-01(I) requires submittal of an operational report no later than the tenth day of the month following the month being reported (e.g. the December monthly operational report must be submitted to the district office no later than January 10.)

The owner/operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I) for not completing the above requirements.

In addition, Fostoria Mobile Estates is classified as a Class A public water system in accordance with OAC Rule 3745-7-03(B)(3). OAC Rule 3745-7-02(A)(1) states "Each person owning or operating a public water system, except as provided in paragraph (B) or (E) of this rule shall designate one or more operator(s) of record to oversee the technical operation of the public water system ... Each operator of record shall have a valid certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant."

A certified Class A operator must be placed in responsible charge of your water system as the operator of record and an operator notification form must be completed and submitted to Ohio EPA. The operator notification form is enclosed.

The owner/operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-7-02(A)(1) for not employing a certified operator to operate and maintain the public water system.

If you have any questions regarding this letter, please contact me at 419-373-3105.

Sincerely,

Curtis A. Eldridge
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Seneca County Health Department
Toni Buchanan, DDAGW, IMS, CO
Tanushree Courlas, DDAGW, CO
~~DDAGW, NWDO, File~~

