



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Fostoria Mobile Estates
Community System
PWS ID. #: 7400712

February 18, 2009

OH7400712

FOSTORIA MOBILE ESTATES

2/18/2009

Mr. Joe Raineri
Fostoria Mobile Estates, LLC
P.O. Box 398
Bath, Ohio 44210



Dear Mr. Raineri:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of January 2009.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The February monthly operational report should be submitted to the district office no later than March 10th].

The owner / operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I) for not completing the above requirements.

In addition, Fostoria Mobile Estates is classified as a Class A public water system in accordance with OAC Rule 3745-7-03(B)(3). OAC Rule 3745-7-02(A)(1) states that, "Each person owning or operating a public water system, except as provided for in paragraph (B) or (E) of this rule, shall designate one or more operator of record to oversee the technical operation of the public water system... Each operator of record shall have a valid certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant."

A certified Class A operator must be placed in responsible charge of your water system as the operator of record and an operator notification form must be completed and submitted to Ohio EPA. The operator notification form is attached to this correspondence.

The owner/operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-7-02(A)(1) for not employing a certified operator to operate and maintain the public water system.

Mr. Joe Raineri
February 18, 2009
Page 2

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

Attachment

pc: Toni Buchanan, IMS, DDAGW, CO
Tanushree Courlas, DDAGW, CO
Lucas Stahl, Fostoria Mobile Estates (with attachment)
Seneca County Health Department
DDAGW, NWDO File —